

**APLAC INTERLABORATORY COMPARISON
PROFICIENCY TESTING PROGRAM**

APM 024

Calibration of Plain Plug Gauges

MEASUREMENT INSTRUCTIONS TO
LABORATORIES

| | |
|--|----------|
| A. INSTRUCTIONS TO LABORATORIES | 2 |
| B. SURFACE CONDITION REPORT OF GAUGES | 4 |
| C. RESULTS SHEET | 7 |

A. INSTRUCTIONS TO LABORATORIES for Circulation Group: C-1

1. EQUIPMENT

Equipment and Accessory Description:

| Group | Content | Serial No. | Nominal Diameter | Material | Manufacturer |
|---|-------------------|------------|------------------|-----------------|--------------|
| C-1 | Plain Plug Gauges | S-62/1 | 5 mm | Steel (EN31) | YPG, UK |
| | | S-62/2 | 15 mm | | |
| | | S-62/3 | 40 mm | | |
| | | S-62/4 | 100 mm | | |
| | Wooden Inner Box | S-62 | - | Wood | YPG, UK |
| Portable Transit Case | - | - | Aluminum | Daedo, Korea | |
| <u>Material property of Plain Plug Gauges :</u> Coefficient of Thermal expansion: $11.6 \times 10^{-6} /K$ Modulus of Elasticity : $206\ 000\ N/mm^2$ | | | | | |

On receipt, unpack the artefacts and inspect them for any defects. Make sure to sketch surface condition of all the artefacts on the "*Surface Condition Report of Gauges*". Contact your accreditation body if there is any damage. Send "*Surface Condition Report of Gauges*" by fax and/or e-mail right away to your accreditation body.

2. MEASUREMENTS TO BE CARRIED OUT

The measurement items of interest are two diametrical distances between the nominal gauge points, defined as mid-elevation along the gauge cylinder and in the diameter direction specified by the engraved marks on the gauge (X-X' and Y-Y'. See Fig. 1).




Fig. 1 Diameter measurement positions

The measurement values must be appropriately corrected to the reference temperature of 20 °C using the thermal expansion coefficient given in this document. Additional corrections, if any, have to be applied according to the equipment and procedures used by each laboratory. And measurement

uncertainty (U) shall be reported by using expanded measurement uncertainty. Coverage factor shall be a value which defines an interval having a level of confidence of approximately 95 %.

After the measurements, the artifacts must be cleaned, greased, and carefully re-packaged in the original container.

3. DOCUMENTS TO BE SUBMITTED

Within one week of the completion of the measurements, participating laboratories are required to send the attached "*Results Sheet*", "*Surface condition report of Gauges*", and their calibration report to their accreditation body. No other documents are required. Laboratories should make a copy of the *Results Sheet* for their own records.

Where possible, uncertainties should be calculated using the method in the ISO *Guide to the Expression of Uncertainty in Measurement*.

4. GENERAL INFORMATION

For general queries, please contact your accreditation body.

Additional information may be obtained from the program coordinator below:

Mr. LEE, Yong-Hoon, technical supervisor

KTL(Korea Testing Laboratory), KOLAS PT provider

1271-12 Sa-dong, Sangnok-gu, Ansan-si, Gyeonggi-do, 426-901, Republic of Korea
Phone No.: +82 31 500 0225

Fax No.: +82 31 500 0244

E-mail: pt@ktl.re.kr

B. SURFACE CONDITION REPORT OF GAUGES

Date:

Name of participant:

Circulation group:

Name of responsible person:


Name of accreditation body:

Please mark: on receipt after measurement

Plain Plug Gauges of nominal diameter 5 mm:

S/N: _____ Please sketch the damage (such as scratches or rusts) and describe it in detail.


< X >




< X' >



< Y >




< Y' >



Plain Plug Gauges of nominal diameter 15 mm:

S/N: _____ Please sketch the damage (such as scratches or rusts) and describe it in detail.


< X >




< X' >



< Y >




< Y' >



Plain Plug Gauges of nominal diameter 40 mm:

S/N: _____ Please sketch the damage (such as scratches or rusts) and describe it in detail.

< X >




< X' >



< Y >




< Y' >




Plain Plug Gauges of nominal diameter 100 mm:

S/N: _____ Please sketch the damage (such as scratches or rusts) and describe it in detail.


< X >




< X' >



< Y >



< Y' >



NOTE: Photograph may be helpful to describe damages well.

C. RESULTS SHEET

Name of participant: _____

Circulation group: _____

Date of measurement: _____

Environment: 1. Temperature _____ 2. Humidity _____

Reference standard (type, S/N, material): _____

Name of accreditation body: _____

Results:

| Nominal diameter (mm) | Gauge S/N | Diameter (mm) | | Measurement uncertainty U (μm) | Coverage factor k | Remarks |
|-----------------------|-----------|---------------|----------|---|---------------------|---------|
| | | $X - X'$ | $Y - Y'$ | | | |
| 5 | | | | | | |
| 15 | | | | | | |
| 40 | | | | | | |
| 100 | | | | | | |

NOTE:

1. Diameter must be reported as a value at the reference temperature of $t_0 = 20\text{ }^\circ\text{C}$
2. Measurement uncertainty (U) shall be reported by using expanded uncertainty.
3. Coverage factor shall be a value which defines an interval having a level of confidence of approximately 95 %.
4. Thermal expansion coefficient: $(11.6 \pm 1.0) \times 10^{-6} /\text{K}$ (Level of confidence: approximately 95 %)
 Modulus of elasticity: 206 000 N/mm².
5. Use SI unit only.

Signature of responsible person: _____

Date: _____ / _____ / _____
 dd mm yyyy